

Pump Test Report

Customer: Larry Dewalt
Well Name: 54454 Bradley Lockwood Rd.
Date: 9/30/2020
Casing: 5" PVC
Total Depth: 377'
Static Water Level: 162.5'
Depth of Pump Set: 360'
Static Recovery Time: 3 Hr 43 Min
Static Recovery Rate: .023' per Min
Length of Pump Test: 6 Hr
Volume of Water Pumped: 6780.22 Gal



186 Call Arroyo
Shandon, CA 93461

	Time	Water Level	GPM
Start	9:06 AM	162.5	-
	9:11 AM	164.8	20.3
	9:15 AM	164.85	20.3
	9:28 AM	164.95	20.3
	9:45 AM	165.1	20.3
	9:57 AM	165	20.3
	10:20 AM	165.1	20.3
	10:50 AM	165.5	20.3
	11:30 AM	165.6	20.3
	12:00 PM	165.7	20.2
	12:30 PM	165.8	20.4
	1:30 PM	166	20.2
	2:30 PM	166	20.1
End	2:55 PM	166	20.2

Test Performed By:
Date: 9-23-2020

Jared Toevs

Thank You!