

**N. Rex Awalt Corporation**

dba AQUA ENGINEERING
PO BOX 398
SAN MIGUEL CA 93451

Phone # (805) 238-1315
awalt@awaltandson.com

Date	Invoice #
9/8/2021	20049

(805) 238-1315

Bill To

Cash Sale
Peter Miao
4 Hr Well Test 0 Sutliff Rd
Paso Robles , CA

09/08/2021

P.O. No.	Terms	Job #
Quoted	Due on receipt	

Description	Quantity	Rate	Amount
4 Hour Well test with pump, pipe& generator rental, install and removal as on quote signed 9/1/2021			
4 Hour Well Test and Bacteria Sample Sales Tax	1	4,610.00 7.25%	4,610.00 0.00

Thank You!!!

Note: All credit card orders or payments will have an additional charge of 3%.
SPECIAL ORDERS ARE NON RETURNABLE.

Total	\$4,610.00
Payments/Credits	-\$4,610.00
Balance Due	\$0.00

Aqua Engineering

Contractors License #896064

950 Mission Street P.O. Box 398 San Miguel, CA 93451

PH. 805-238-1315 FX. 805-467-9520

Well Test Report Form

Date: 9/23/2021 Jeff Chavarria Realtor
805-423-7242

Customer: Peter Miao by Christine A Bruney
Address: 16668 Juarez Dr.
San Diego, CA 92128-2730

Job Location: O Sutliff Road Off Nygren, San Miguel, CA 93451
Time at start of test: 09:00am End 1:00pm
Hours in service: 4
Static level at start of test: 293'
Recovery Level: 291.43'
HP pf pump installed: 5HP Test Pump
Results:

<u>Time</u>	Pumping <u>Level</u>	<u>GPM</u>	<u>Notes</u>
9:00:00 AM	293'	21	Clear
9:10:00 AM	296'	21	Clear
9:20:00 AM	296'	21	Clear
9:30:00 AM	296'	21	Clear
9:40:00 AM	296'	21	Clear
9:50:00 AM	296'	21	Clear
10:00:00 AM	296'	21	Clear
10:15:00 AM	299'	21	Clear
10:30:00 AM	299'	21	Clear
10:45:00 AM	299'	21	Clear
11:00:00 AM	299'	21	Clear
11:20:00 AM	299'	21	Clear
11:40:00 AM	299'	21	Clear
12:00:00 PM	299'	21	Clear
12:30:00 PM	299'	21	Clear
RECOVERY			
12:35:00 PM	293'	21	

12:45:00 PM	293'	21
1:00:00 PM	293'	21

Thank you for allowing Aqua Engineering the opportunity to test your water well.
If you have any questions regarding your test, please don't hesitate to call.

This well test is guaranteed to be accurate as of the above testing date. The Contractor makes no warranties or guarantees as to water quantity or gallons per minute subsequent to the test date. Contractor makes no guarantees or warranties as to potability. The lab conducting the potability testing is solely & exclusively responsible for the results thereof.

Payment Receipt

N. Rex Awalt Corporation
dba AQUA ENGINEERING
PO BOX 398
SAN MIGUEL CA 93451

Received From:

Cash Sale
Cash Sale
Peter Miao
4 Hr Well Test 0 Sutliff Rd
Paso Robles , CA

Date Received	09/08/2021	Payment Amount	\$4,610.00
Payment Method	Check		
Check/Ref. No.	8600		

Invoices Paid

Date	Number	Amount Applied
09/08/2021	20049	-\$4,610.00