

Miller Drilling Co.
 329 N. Main St.
 Templeton, CA 93465
 (805) 434-1888

Miller Drilling Co.

Contractors License No. 324634

PUMP TEST REPORT

Job#: 28454
 WELL OWNER: Estate of Carl Treise Pump Set: 35' Well #: 8"
 BILLING ADDRESS: PO BOX 1492 Pump Size: 2HP Well Depth: 42'
San Luis Obispo, CA 93406 Testing Method: Existing Pump
terrymathis@earthlink.net Perf Rec: _____
 APN: 070-351-031
 Standing Level Before Test: 14 FT LOCATION: 4555 Las Pilitas

TESTING

TIME	PUMPING LEVEL	WATER CONDITION	WATER/BOWLS	GPM
8:45 AM	19 FT	CLEAR NO ODOR		34
8:50 AM	20 FT	CLEAR NO ODOR		34
8:55 AM	20 FT	CLEAR NO ODOR		34
9:00 AM	20 FT	CLEAR NO ODOR		34
9:10 AM	20 FT	CLEAR NO ODOR		33.5
9:20 AM	21 FT	CLEAR NO ODOR		33
9:30 AM	21 FT	CLEAR NO ODOR		32
9:40 AM	21 FT	CLEAR NO ODOR		32
9:50 AM	21 FT	CLEAR NO ODOR		32
10:00 AM	21 FT	CLEAR NO ODOR		32
10:30 AM	21 FT	CLEAR NO ODOR		32
11:00 AM	21 FT	CLEAR NO ODOR		32
11:30 AM	21 FT	CLEAR NO ODOR		32
12:00 PM	21 FT	CLEAR NO ODOR		32
12:30 PM	21 FT	CLEAR NO ODOR		32
12:45 PM	21 FT	CLEAR NO ODOR		32
1:00 PM	17 FT			

Notes: _____

STANDING LEVEL AFTER TEST: 17 FT AFTER 15 MIN RECOVERY
 FINAL TEST RESULTS: Produced: 32.1 GPM for 4 hours on: 1/24/2024
 Test Run By: Braden & Harold

Abalone Coast Analytical, Inc.

141 Suburban Rd, Ste C-1 San Luis Obispo CA, 93401

Phone: 595-1080 Fax: 595-1075

ELAP #2661

Order #: 24-0432

Date/Time Rec'd: 1/25/24 1326

Miller Drilling Company
301 North Main Street
Templeton, CA 93465


Contact: Eric Thomas
Phone: 434-1888
Sampler: Braden L

Project:

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	#28454-Estate of Carl Tresie	1/25/24 0830	Total Coliform	SM 9223 B.	Absent	/100ml	1	01/26/24
	4555 Las Piiltas		E-coli	IDEXX	Absent	/100ml	1	01/26/24

This sample passes water quality standards for Total Coliform and E. Coli Bacteria.

Report Completion Date: 1/26/24

Reviewed By: 

Priyanka Singh, Technical Director

Definitions:

Absent = Less than 1 CFU/100mLs

Present = 1 or more CFU/100mLs

CFU = Colony Forming Unit

RL = Reporting Limit

State of California CDPH ELAP 2661

Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.