

State of California
Well Completion Report
 Form DWR 188 Submitted 7/17/2020
 WCR2020-009143

Owner's Well Number _____ Date Work Began 07/13/2020 Date Work Ended 07/14/2020
 Local Permit Agency San Luis Obispo County Environmental Health Services
 Secondary Permit Agency _____ Permit Number 2020-066 Permit Date 07/02/2020

Well Owner (must remain confidential pursuant to Water Code 13752)

Name BRIAN HOLLAND
 Mailing Address 896 TAMLEI AVE
 City THOUSAND OAKS State CA Zip 91362

Planned Use and Activity

Activity New Well
 Planned Use Water Supply Domestic

Well Location

Address 4575 INTERLAKE RD APN 080-034-028
 City BRADLEY Zip 93426 County San Luis Obispo Township _____
 Latitude 35 46 50.736 N Longitude -120 55 3.5399 W Range _____
 Deg. Min. Sec. Deg. Min. Sec. Section _____
 Dec. Lat. 35.78076 Dec. Long. -120.91765 Baseline Meridian _____
 Vertical Datum _____ Horizontal Datum WGS84 Ground Surface Elevation _____
 Location Accuracy _____ Location Determination Method _____ Elevation Accuracy _____
 Elevation Determination Method _____

Borehole Information

Orientation Vertical Specify _____
 Drilling Method Direct Rotary Drilling Fluid Bentonite
 Total Depth of Boring 400 Feet
 Total Depth of Completed Well 400 Feet

Water Level and Yield of Completed Well

Depth to first water 60 (Feet below surface)
 Depth to Static _____
 Water Level _____ (Feet) Date Measured 07/14/2020
 Estimated Yield* 30 (GPM) Test Type Air Lift
 Test Length 3 (Hours) Total Drawdown _____ (feet)
 *May not be representative of a well's long term yield.

Geologic Log - Free Form

Depth from Surface Feet to Feet		Description
0	3	TOPSOIL
3	74	BROWN CLAY- STICKY
74	106	BROWN SHALE
106	114	GRAY SANDSTONE
114	120	BLUE GRAY CLAY
120	137	GRAY SANDSTONE WITH SOME SMALL GRAY CLAY
137	171	HARD GRAY SANDSTONE
171	180	BROWN SHALE
180	186	GRAY SANDSTONE
186	233	BROWN SHALE
233	315	GRAY SANDSTONE
315	400	BROWN SHALE

Casings										
Casing #	Depth from Surface Feet to Feet		Casing Type	Material	Casings Specificatons	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	160	Blank	PVC	OD: 5.563 in. SDR: 21 Thickness: 0.265 in.	0.265	5.563			
1	160	400	Screen	PVC	OD: 5.563 in. SDR: 21 Thickness: 0.265 in.	0.265	5.563	Saw Cut	0.04	

Annular Material					
Depth from Surface Feet to Feet		Fill	Fill Type Details	Filter Pack Size	Description
0	65	Cement	Portland Cement/Neat Cement		
65	400	Filter Pack	8 x 12	SAND	

Other Observations:

Borehole Specifications		
Depth from Surface Feet to Feet		Borehole Diameter (inches)
0	400	10

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief			
Name	FILIPPONI-THOMPSON DRILLING INC		
	Person, Firm or Corporation		
	P O BOX 845	ATASCADERO	CA 93423
	Address	City	State Zip
Signed	<i>electronic signature received</i>	07/17/2020	432680
	C-57 Licensed Water Well Contractor	Date Signed	C-57 License Number

DWR Use Only			
CSG #	State Well Number	Site Code	Local Well Number
		N	W
Latitude Deg/Min/Sec		Longitude Deg/Min/Sec	
TRS:			
APN:			